

Minimum Requirements for Electrical Service Replacement and New Service Energizing

In an effort to assist the public with clearance to energize existing as well as new electrical services, Apache County Building Safety has compiled the following minimum service requirements:

- An electrical permit **MUST** be issued by Apache County
- Over-current protection devices must be properly sized for the conductors
- Conductors must be landed and secured in the proper locations
- Correctly sized feeder conductors must be in place
- Permanent labeling of the circuits must be completed
- Permanent physical address must be located on the Service entrance system
- System grounding electrode conductor(s) must be installed

Apache County Building Safety will issue a “green tag” or clearance to energize upon inspection and verification of the above mentioned items. Any minimum requirements not being met upon inspection will result in inspection failure and request for service will be denied.